

EU Declaration of conformity

according to Directive 2014/68/EU

for a pressure equipment

The manufacturer

IVR S.p.A.

Via Brughera III, 1 – 28010 Boca (NO) - Italy

herewith declares, that the pressure equipment

Description:	Ball valves, per product lines	
Type-, serial-, identification-No:	82106, 82101, 82102, 82105, 82100, 26003, 26004, 26005, 26011, 26023, 26024, 26025	
Year of manufacturing:		
Chamber designation:		
max. allowable pressure PS:	25	bar
allowable max./min. temperature TS:	+90 max, -20 min	°C
Volume / Diameter	½" to 2"	inch
Test pressure PT:	35,75	bar
Pressure test date:	10.-12.07.2017	
Pressure test medium:	water	
Fluid – fluidgroup:	2	

corresponds to the Pressure Equipment Directive 2014/68/EU.

Applied conformity assessment procedures:

Modul A

Applied standards and technical specifications:

AD2000, pressure test according to DIN EN 12266-1:2012-06 part 1

Other applied EC-Directives:

Engaged notified bodies

Surveillance of the QS-System:

Internal manufacturing control

Examination / inspections / test during manufacturing:

Certificates which are included

Test report no.

Test report for pressure test IS-ESK2/17/43

Location, Date: Boca, 06/10/2017

Umberto Savoini, Quality Manager

IVR S.p.A.
Via Brughiera III, 1 - LOC. PIANO ROSA

Signature: 28010 BOCA (NO)